



Office of the President of the Philippines
OFFICE OF THE PRESIDENTIAL ADVISER ON THE PEACE PROCESS

REQUEST FOR QUOTATION

25 November 2021

The Office of the Presidential Adviser on the Peace Process (OPAPP) through the General Appropriations Act of FY 2020 intends to apply the sum of Four Hundred Thousand Pesos (PhP400,000.00) being the Approved Budget for the Contract (ABC) to be paid for the Negotiated Procurement – Small Value Procurement, as defined under Section 53.9 of the IRR of RA 9184 for the Procurement of 25kVA Generator Set for the Secured Arms Storage Area (SASA) in Camp Iranun, Barira, Maguindanao listed below:

Lot	Goods	Quantity	Specific Technical Requirements
	25kVA Generator	1	See Annex "A"

The OPAPP now invites contractors/suppliers to submit price quotations for the above items.

The Contract will be awarded **per lot** to the **lowest quotation** and **responsive** to the specifications and requirements.

For further inquiries, please coordinate with the BAC Secretariat at telephone number (02) 8636 0706 local 871 or at bac.secretariat@peace.gov.ph.

Sincerely,

MOCTAR B. ABUBAKAR
PDO IV, IDB

Noted by:

ANNA FARINA PACETE-MARUNDAN
PPO V, IDB

TERMS AND CONDITIONS

- a) The ABC is inclusive of applicable taxes, fees, and/or levies payable.
- b) The contract shall be awarded to the lowest and responsive bid. Bid amount exceeding the ABC shall be automatically disqualified.
- c) The price quotation must be valid for sixty (60) calendar days from the date of submission of bids.
- d) Bidder shall submit its quotation and the following documents with all its pages on or before **06 December 2021 10:00AM** on the place specified below:
 - 1. Mayor's/Business Permit
 - 2. PhilGEPS Registration Number
 - 3. Omnibus Sworn Statement (*Original Copy*)

None submission of any or all the document will be declared ineligible to bid and hence, the bid shall be disqualified.

The above documents shall be submitted in a sealed envelope with the name of the sender, complete mailing address, email address, and telephone or mobile number. Without such details, the bid shall not be accepted.

Submit your bidding documents at:

*BAC Secretariat Office
3rd Floor, Agustin I Building
F. Ortigas Jr. Road
Ortigas Center
Pasig City*

- e) Late bids will not be accepted. If you intend to send your bids through a courier, please ensure that we shall receive it before the deadline submission of bids.
- f) OPAPP shall conduct evaluation/inspection of goods to be supplied to OPAPP before an award shall be issued.
- g) Subcontracting is not allowed.
- h) Delivery shall be completed within twenty (20) calendar days from receipt of Job/Purchase Order.
- i) Place of Delivery

No. 19 San Isidro Avenue, Rosary Heights 10, Cotabato City

- j) Payment shall be made to the supplier or distributor within thirty (30) calendar days from complete delivery and submission of pertinent documents for payment as required under existing laws.
- k) Replacement of defective item/s shall be made within seven (7) days from receipt of the supplier or distributor of the formal written notice.
- l) OPAPP reserves the right to reject any and all quotations or bids, declare a failure of bidding or not award the contract in accordance with Section 41 of the IRR of RA 9184.

QUOTATION FORM

OFFICE OF THE PRESIDENTIAL ADVISER ON THE PEACE PROCESS
Agustin I Building
F. Ortigas Jr. Road
Ortigas Center, Pasig City

Dear **Sir/Ma'am**:

After having carefully read and accepted your terms and conditions, we are pleased to quote you for the following items:

Lot	Technical Requirements	Quantity	Statement of Compliance	Unit Cost	Total Cost
	25kVA Generator (See Annex "A")	1			

Prices in the above offer are certified true and correct.

Sincerely,

(Signature over Printed Name of the Authorized Representative)

Company Name: _____

Contact No: _____

Email Add: _____

TECHNICAL SPECIFICATIONS FOR THE PROCUREMENT OF ONE (1) 25KVA GENERATOR SET:

Generator Specifications:

Genset Output (KVA / KW)	25 / 20
Engine rating or Max. Power at rated RPM, in KW (BHP)	24.72 (33.6)
Engine Model	G-25-II
Engine Type	TCAC
No. of Cylinders / Cylinder arrangement	3 / Inline
Displacement (L)	2.14
Bore & Stroke (mm)	91X110
Compression ratio	17.5
Rated RPM	1500
Governor: Type /Class of Governing	Mechanical/G2
Over speed trip (rpm)	1650
Air cleaner type / Qty	Dry / 01

Exhaust system:

Maximum allowable back pressure, kPa	5.5
--------------------------------------	-----

Alternator Specification:

Voltage	380-440V
Frequency	50Hz
Current @ 0.8PF (Amps)	108.6/34.7
Type	4 Pole , Rotating field
Exciter Type	Brushless
Leads: Quantity, type	6, fixed. 12, re-connectable (optional)
Voltage regulator	Solid State
Insulation	Class H
Temperature rise	125 Deg. C (Class H)
Bearing: Quantity, type	1, Sealed
Coupling	Flexible disc, close coupled
Voltage regulation: No load to full load	2 Phase sensing, ±1%
One step load acceptance	100% of rating
Unbalance load capability	25% of rated current

Engine Electrical system:

Charging alternator Voltage / Current (DC)	12V / 35Amps
Starter Motor rated voltage (DC)	12
Battery Voltage (DC) / Capacity (AH)	12V,88AH

Fuel System:

Recommended Fuel	HSD
Fuel tank capacity (Ltr)	75
Fuel consumption - LPH at % load	
100%	6.3
75%	5.0
50%	4.1
25%	2.6

Lubricating Oil System:

Lube oil sump capacity	6.5
Oil change period (Hrs)	500
Oil consumption (%SFC)	≤0.1
Oil filter quantity (Nos) /type	01 / spin on type
Oil Cooler	NA

Cooling System:

Cooling system is designed for max ambient temp, Deg. C at rated load	50
Radiator System capacity, including engine, (L)	12.5 Ltr
Water pump type	Engine mounted